



**ADDENDUM NO. 1**

to the

**CONTRACT DOCUMENTS**

for

**CITY OF POCA TELLO  
WELL #2R AND WELL #22R**

This Addendum dated January 23, 2024 is for all persons preparing bids for the above referenced project and as such shall be made a part of the Contract Documents.

All changes, corrections, deletions and/or additions to the initial bidding documents enumerated herein shall be included in the Bidder's Proposal. In case of any conflict between the drawings, specifications, and this Addendum, this Addendum shall govern.

**The Bidder shall acknowledge the receipt of this Addendum in the appropriate place in the Bidder's Proposal. Failure to acknowledge the receipt of this Addendum will cause a Bid to be considered non-responsive.**

***SPECIFICATIONS***

---

**Item    Description**  
**1-1      SECTION 00 11 16 – INVITATION TO BID**

**REVISE** – Paragraph 2 to read as follows:  
BIDS will be received until **2 P.M.** Local Mountain Daylight Time, on **February 13, 2024**, and then at said office publicly opened and read aloud shortly thereafter. A contract will be awarded or bids rejected within 45 days of the bid opening.

**1-2      SECTION 01 11 00 – SUMMARY OF WORK**

**REVISE** – Paragraph 1.2.B.1.p. to read as follows:  
p. Installation of Well Pump and Motor

**REVISE** – Paragraph 1.2.B.2.p. to read as follows:  
p. Installation of Well Pump and Motor

**REVISE** – Paragraph 1.4.A.1 to read as follows:

1. The Contractor is to purchase and install the vertical turbine pumps and motors for the project.

### **1-3 SECTION 43 30 50 – DEEP WELL-LINE SHAFT TURBINE PUMP**

**REVISE** – Part I Paragraph 1.1.A to read as follows:

**A. Both Well Pumps and associated motors (PMP-A001 & PMP-B001) are to be supplied by the Contractor. Contractor is responsible for installing the pumps and motors and incorporating them into each Well House startup. This specification provides information on the materials that the Contractor will be supplying and installing along with what is shown in the drawings.**

**REVISE** – The last sentence of 1.6.A to read as follows:

- A. The Contractor shall obtain and pay for the factory representative services.

**REVISE** – The first sentence of 3.2.A to read as follows:

- A. The Contractor shall secure start-up services for the pumps as specified under Paragraph 1.6 above and the tests required below in 3.2.B, 3.2.C and 3.2.D.

## **DRAWINGS**

---

<b><u>Item</u></b>	<b><u>Description</u></b>
--------------------	---------------------------

<b>1-4</b>	<b>SHEET E-121-A</b>
------------	----------------------

**REVISE** – Bar Scale to show in upper right-hand corner of the sheet to be 1" = 20'. Numbers on this scale should be 0, 20 and 40.

<b>1-5</b>	<b>SHEETS M-101-A, M-301-A, M-302-A</b>
------------	---

**REVISE** – Equipment Keynote “PMP-A001” to read as follows:

VERTICAL TURBINE PUMP, 250 HP; RE: SPEC 43 30 50, PROVIDED AND INSTALLED BY CONTRACTOR

<b>1-6</b>	<b>SHEETS M-101-B, M-301-BA, M-302-B</b>
------------	--

**REVISE** – Equipment Keynote “PMP-B001” to read as follows:

VERTICAL TURBINE PUMP, 350 HP; RE: SPEC 43 30 50, PROVIDED AND INSTALLED BY CONTRACTOR

1-7 SHEET M-503, DETAILS M905 and DETAIL M906

**REMOVE** – “OWNER PROVIDED” after the note for STAINLESS STEEL STRAINER (BY PUMP MANUFACTURER), the note for FABRICATED PUMP DISCHARGE HEAD (BY PUMP MANUFACTURER) and the note for PUMP COLUMN.

**QUESTIONS/CLARIFICATIONS**

---

1. **PUMP STARTUP PROCEDURES** All pump startup procedures will be the responsibility of the Contractor.
2. **PUMP WARRANTY RESPONSIBILITIES** Since the Contractor is now providing the pumps and motors, all associated warranties will be the Contractor's responsibility.



---

**KELLER ASSOCIATES, Inc.**  
305 N. 3rd Avenue, Suite A  
Pocatello, ID 83201