



ADDENDUM NO. 2

February 28, 2022

**PROJECT: Horizon Elementary School Addition
Jerome School District
Jerome, Idaho**

The following addenda apply to the Drawings and/or Specifications for this project and shall be a part of the Contract Documents.

PROJECT MANUAL

SPECIFICATION SECTION – 087100 DOOR HARDWARE

1. General Clarification: The hardware supplier shall supply all door cylinders (Dormakaba Best – CoreMax, to match existing) and the Owner will provide the small format interchangeable keyway / core.
2. Refer to 2.6.A, delete the requirement to provide a “Key Control Cabinet”.
3. Refer to 2.6.P, delete the requirement to provide an “Electronic Key Management System”.
4. Refer to 2.9 Conventional Exit Devices. Add cylinder dogging.
5. Refer to 2.10 Electromechanical Exit Devices, Add that any dogging would be electronically dogged at the exit device.

- End of Addendum No. 2 -